

Little Rock Water Reclamation Authority

Local Limits

Environmental Assessment Department

PARAMETER	Monthly Average	Daily Max
	mg/L	mg/L
Arsenic	0.14	0.14
Cadmium	0.2	0.4
Chromium	5.0	5.0
Copper	5.0	5.0
Cyanide	1.8	3.6
Lead	1.3	2.6
Mercury	0.002	0.002
Nickel	4.9	5.0
Selenium	0.1	0.1
Silver	2.0	4.0
Zinc	4.8	5.0

Sewer Use Ordinance #19,895 Section 2.4